

CUWCD CWP Well House #7			
DESCRIPTION	SURGE VAULT	ELECTRICAL	TOTAL
LIGHTING			
F1	0	6	6
F2	2	1	3
F3	0	4	4
F4	0	2	2
F5	0	1	1
F6	0	4	4
PHOTOCELL	0	1	1
GEAR			
MSD 15KV/200A/3P/4W/NEMA 3R/LOCKABLE/65KAIC	0	1	1
POWER MONITOR FOR MAIN SERVICE DISCONNECT	0	1	1
SWITCHGEAR 15KV/2-200A/3P/4W/NEMA 3R/65KAIC	0	1	1
TRANSFORMER H 150KVA/15KV/480Y/277	0	1	1
TRANSFORMER L 45KVA/480V/208Y/120	0	1	1
PANELBOARD H 250A/480V/277/3P/4W/NEMA 1/22KAIC	0	1	1
PANELBOARD L 225A/208Y/120/3P/4W/NEMA 1/10KAIC	0	1	1
TRANSFORMER PRV 25KVA/480V/240/120	0	1	1
VFD FEEDER DISCONNECT 200A KIRK KEY WITH DISC.	0	1	1
TRANSFORMER H DISCONNECT 200A	0	1	1
100A MAIN CIRCUIT BREAKER FOR EXISTING SEIMENS PANEL SEE PHOTO 3 ON SHEET E4.1	0	1	1
DISCONNECT 100A/600V/NEMA 3R	0	1	1
DISCONNECT 60A/N1/3P/600V	0	1	1
DISCONNECT 60A/N3R/2P/250V	0	1	1
DISCONNECT 30A/N1/2P/250V/FUSED	0	3	3
MANUAL STARTER 30A	0	1	1
CONTROL PANELS			
CP-07-04	0	1	1
CP-07-03	0	1	1