

City Creek Water Treatment Plant - BRIC 90_GMP

DESCRIPTION	SITE	SECTION 01	SECTION 35 LL	SECTION 35 UL	Section 70 intermediate lvl	section 70 upper LL	Section 60 Clarifier	Power Schedule totals	SECTION 89	TOTAL
LIGHTING										
FIXTURE TYPE - A1	0									0
FIXTURE TYPE - AL1E	0		4			0				4
FIXTURE TYPE - AF1				10		5				15
FIXTURE TYPE - MF1				41		5				46
FIXTURE TYPE - MF2				41		10				51
FIXTURE TYPE - SF1			19		28	21				68
FIXTURE TYPE - W			4							4
FIXTURE TYPE - X1			3	5	2					10
FIXTURE TYPE - X2					1	4				5
FIXTURE TYPE - X3				1	1					2
OCUPANCY SENSOR CEILING			5	8		7				20
OCUPANCY SENSOR WALL MOUNT WITH SWITCH			1							1
GEAR										
MCC-2155 / 480/277 / 3P 4 WIRE / KAIC65 / 800A BUS /600A MB								1		1
SWG-2140								1		1
87-LP-2200								1		1
TRANSFORMER-2200/ 480V/30KVA, 208/120V								2		2
DISCONNECT SWITCH / 600V / 3P / 3-POLE / 30A /N-4X / FUSIBLE, FUSED AT 20A								84		84
DISCONNECT SWITCH / 600V / 3P / 3-POLE / 30A /N-12 / FUSIBLE, FUSED AT 20A								3		3
DISCONNECT SWITCH/ 600V /3P /3-POLE/100A /N-12/ FUSIBLE, FUZED AT 100A								1		1
DISCONNECT SWITCH/ 600V / 3P/3 POLE/ 200A/ N-12/FUSIBLE , FUZED AT 200A								3		3
DISCONNECT SWITCH/ 600V / 3P/ 3-POLE/ 400A /N-12/ FUSIBLE/ FUZED AT 400A								1		1