

## Provo WRF Electrical Upgrades

| DESCRIPTION                                     |  | TOTAL |
|-------------------------------------------------|--|-------|
| PACKAGE A                                       |  |       |
| PANEL C 125A/1P/10KAIC                          |  | 1     |
| TRANSFORMER 25KVA/480V TO 240/120V/1P           |  | 1     |
| MCC-C 400A/480V/3P/3W/65KAIC/N12                |  | 1     |
| 400A LOAD CENTER CIRCUIT BREAKER                |  | 1     |
| PACKAGE B                                       |  |       |
| SE-NSG-001A                                     |  | 1     |
| 800A CIRCUIT BREAKER FOR MCC-CF                 |  | 1     |
| PACKAGE C                                       |  |       |
| HW-NTR-001A 500KVA KNAN/12.47KV TO 480/277V/3PH |  | 1     |
| HW-MCB-001A 42KAIC/480V/277V/3P/4W/400AT/400AF  |  | 1     |
| PAD MOUNTED SWGR NORTH SE-NSG-001A              |  | 1     |
| PACKAGE D                                       |  |       |
| SE-SSX-001A                                     |  | 1     |
| SE-SSG-001A                                     |  | 1     |
| PACKAGE E                                       |  |       |
|                                                 |  |       |