

LEHI LOW HILLS PUMP STATION

DESCRIPTION						TOTAL
LIGHTING						
F1		6				6
F1E		2				2
F2		3				3
GEAR						
SWITCHBOARD SWB 2000A/277/480V/3P/4W/42 KAIC/NEMA 3R		1				1
TRANSFORMER 30KVA.480-208/120V/3P		1				1
PANEL "L" 125A/120/208V/3P/4W/10 KAIC		1				1
400 HP VFD		3				3
200 HP VFD		2				2
DISCONNECT SWITCH 30A/3P/NEMA 3R/600/HD		2				2