

JVWCD 1000 East Well Site

DESCRIPTION	TOTAL
LIGHTING	
F1	16
F2	4
GEAR	
MAIN SERVICE DISCONNECT 15KV, 600A RATED SWITCH NEMA 3R LOCKABLE ENCLOSURE	1
TRANSFORMER T3, 300KVA, OIL FILLED PAD TRANSFORMER, 12,470V PRIMARY, 480Y/277 V SECONDARY	1
TRANSFORMER T4, 15KVA, 480V PRIMARY, 120/240V SECONDARY	1
TRANSFORMER T1 112.5 KVA, PAD MOUNTED, OIL-FILLED 12,470 V PRIMARY, 480.277 V SECONDARY POWER	1
TRANSFORMER T2, 30KVA, 480V PRIMARY, 208Y/120V SECONDARY 3-PH, 4W	1
PANEL BOARD L, 225A, 208/120V, 3PH, 4W, NEMA1	1
PANEL BAORD H, 480V, 225A, 3-PH, 4W, NEMA 1	1
PANELBOARD H2, 480V, 600A, 3-PH, 4W, NEMA 3R	1
PANEL L2, 125A, 240/120V, 1-PH, NEMA 1	1
MDP-2, 800A, 480V, 3-PH, NEMA 3R, 42KAIC	1
PMDE-2 200 AMP, 12,470V, 3-PH, NEMA 3R	1
PMDE-1 600A, 12,470V, 3-PH, NEMA 3R	1
VFD-1 100A, 12,470V, 3-PH	1
CONTROL PANELS	
CP-4, 120V, 1-PH, NEMA 12	1
CP-5 480V, NEMA 1, 3-PH	1
EE-1 240/180V, 1-PH, NEMA 4X FIBERGLASS	

JVWCD 700 East Well Site

DESCRIPTION	TOTAL
LIGHTING	
F1	15
F2	6
HAPCO S5976-AK3UBG1505A , VS70 MOD TYPE III ACORN GLOBE SINGLE ACORN S6936	1
HAPCO ITEM #77509BPP1, POL, AL, PED, 5/22/E, 18 MH, BLK	1
GEAR	
DISCONNECT, 240V, 60A, 2 POLE, 3W NEMA 3R	1
MAIN SERVICE DISCONNECT, 600V, NEMA 3R ENCLOSURE	1
PANEL BOARD H 225A, 480V, 3-PH, 4-W, NEMA 1	1
PANEL BOARD L 240V, 225A, 3-PH, 4-W, NEMA 1	1
TRANSFORMER T3, 10KVA, 480V PRIMARY 120/240V SECONDARY	1
TRANSFORMER T2, 15KVA, 480V PRIMARY 208/120V SECONDARY	1
VFD 480 VAC, 3-PHASE WITH MATRIX HARMONIC FILTER NEMA 1 ENCLOSURE	1
PANEL BOARD MDP, 800A, 600V, 3-PH, 4W, NEMA 1 ENCLOSURE	1
CONTROL PANELS	
CP-6,120V, SINGLE PHASE, NEMA 4X	1
CP-5 120V, NEMA1, 1-PH	1
EE-1 240/120V, NEMA 4X, 1-PH	1