MWDSLS AQUIFER STORAGE AND TESTING COUNTS		
GEAR		
MDP 800A/480/277V/3P/4W/NEMA 12/22 KAIC		1
TRANSFORMER 12470-480/277 DELTA-WYE/3P/4.5%		1
TRANSFORMER L 30KVA/3P/480-208V/120V		1
NEMA 12 GASKETED ENCLOSURE W/ VFD & ACTIVE HARMONICS		1
PANEL L 125A/208V/NEMA 12 GASKETED/10 KAIC		1
FIXTURES		
F1		4
F2		2