

Saratoga Springs Drinking Water Booster Station

| DESCRIPTION | Pump Station | SITE | TOTAL |
|---|--------------|------|-----------|
| LIGHTING | | | |
| F1 | 13 | 0 | 13 |
| F1E with 90 minute Battery Backup | 3 | 0 | 3 |
| F2 | 6 | 0 | 6 |
| F3A | 0 | 4 | 4 |
| F3B | 0 | 4 | 4 |
| GEAR | | | |
| SES - 1600A / 480VAC / 3PH / 4W / 65KAIC / SPD / NEMA3R / W/METER | 0 | 1 | 1 |
| MDP / 1600A /TYPE QED-2 / 480/277 / 3PH / 4W /NEMA1 / 65KAIC /SURGE PROTECTED | 1 | 0 | 1 |
| TRANSFORMER L: 25KVA/480-120/240V / 2PH / 3W | 1 | 0 | 1 |
| MANUAL MOTOR STARTERS | 0 | 0 | 0 |
| DISCONNECT/60A/2P/HEAVY DUTY/FUSED/NEMA3R | 1 | 0 | 1 |
| DISCONNECT/60A/3P/HEAVY DUTY/FUSED/NEMA3R | 1 | 0 | 1 |
| DISCONNECT/30A/3P/HEAVY DUTY/ NON FUSED / NEMA1 | 4 | 0 | 4 |
| PANELS | | | |
| PANEL H / 225A / 110A MCB / 42 CIR / 120/240 / 2P / 3W / NEMA1 / 10KAIC | 1 | 0 | 1 |
| PANEL L / 125A / MLO / 42 CIR / 277/480 / 3PH / 4W / NEMA1 / 10KAIC | 1 | 0 | 1 |
| | | | |