

SOUTH SALKT LAKE MARKET STATION PS						
DESCRIPTION	LOWER LEVEL	MAIN LEVEL				TOTAL
LIGHTING						
F1		6				6
F1E		2				2
F2	5					5
F2E	2					2
F3		5				5
F4	1	2				3
GEAR						
800A CT ENCLOSURE		1				1
UTILITY METER		1				1
SERVICE DISCONNECT 800A/3P/600V/NEMA 3R/NF/HD		2				2
MDP 800A/480/277/3P/4W/22KAIC		1				1
VFD 125HP		3				3
VFD 15HP		2				2
DISCONNECT SWITCH 30A/3P/NF/NEMA 3R/600V/HD (NOTE 2 & 6 ON E-601)		2				2
TRANSFORMER 45KVA/480-208/120V/3P		1				1
PANEL "L" 208/120V/3P/4W/10KAIC		1				1
COMBINATION FUSED SWITCH 30A/NEMA 3R/HD/600V (NOTE 1 ON E-601)		1				1
DISCONNECT SWITCH 30A/3P/FUSED/NEMA 3R/600V/HD (NOTE 3 & 4 ON E-601)		3				3
GENERATOR DISCONNECT 200A/480/277V/NEMA 3R		1				1
DISCONNECT SWITCH 60A/3P/FUSED/NEMA 1/250V/HD/CLASS 1 DIV 2 (NOTE 5 ON E-601)		2				2
AERIGATOR SOFT STARTER		2				2
GENERATOR						
STANDBY GENERATOR 600KW/480/277V	1					1
ATS 800A/480V/3P/22KAIC	1					1